

KSPH&IDCL	Format for water testing for Construction Purpose	F : 14-1 Rev. No. 1 Page 1 of 1
----------------------	--	--

Name of work:

Date:

Name of the Contractor:

Location :

Reference to test report :

SI No	Particulars	Test results	Permissible limits
1	<p>pH value</p> <p>Organic impurities</p> <p>Sulphates Not more than 0.05% by weight of water</p> <p>Alkali Chlorides</p>		<p>6 - 8</p> <p>not greater than 0.02% by weight of water</p> <p>not greater than 0.05% by weight of water</p> <p>not greater than 0.10 % by weight of water</p>

Water sample tested is OK / Not OK

Contractor

JE / AE (KSPH&IDCL)